



Materials/Finishes:	Pre-Galvanized (168G)	T-304 Stainless Steel (168SS)
	T-316 Stainless Steel (168SX)	
Variants:	N/A	
Service:	Designed for outside of foam or fiberglass insulation on stationary pipe lines (not designed for pipe rollers) to prevent crushing of insulation without breaking the vapor barrier.	
Approvals:	N/A	
Ordering:	Specify figure number and shield size. MINIMUM ORDER OF 100 PCS.	
Notes:	N/A	

SHIELD SIZE NO.	B LENGTH	C STOCK SIZE	D DIA.	HANGER SIZE	WGT EACH (lbs)
0	8	18ga	1-7/8	11/2	0.32
1	8	18ga	2-3/8	2	0.40
2	8	18ga	2-7/8	2 1/2	0.50
3	8	18ga	3-1/2	3	0.63
4	8	18ga	4	3 1/2	0.70
5	8	18ga	4-1/2	4	0.77
6	8	18ga	5	5	1.00
7	8	18ga	5-9/16	5	1.10
8	8	18ga	6-5/8	6	1.25

PIPE SIZE	A - INSULATION THICKNESS				
	1/2"	3/4"	1	1-1/2"	2
1/2	0	1	-	-	-
3/4	1	1	2	4	6
1	1	2	3	5	7
1-1/4	2	3	3	6	7
1-1/2	2	3	4	6	8
2	3	4	5	7	8
2-1/2	4	5	6	7	8
3	5	6	7	8	9
3-1/2	-	-	8	9	10
4	-	-	8	9	10
5	-	-	9	10	13
6	-	-	10	13	14
8	-	-	14	15	16
10	-	-	16	17	18
12	-	-	18	19	20
14	-	-	19	20	21
16	-	-	21	22	23
18	-	-	23	24	25
20	-	-	25	26	27
24	-	-	28	29	30

TUBING SIZE	A - INSULATION THICKNESS				
	1/2"	3/4"	1	1-1/2"	2
1/2	0	1	2	4	5
3/4	0	1	2	4	6
1	1	2	3	4	6
1-1/4	1	2	3	5	7
1-1/2	2	3	3	5	7
2	3	4	4	6	8
2-1/2	4	5	5	7	8
3	5	6	6	8	9
3-1/2	6	7	7	8	9
4	7	7	8	9	10
5	8	8	9	10	13
6	9	9	10	13	14

PROJECT INFORMATION	APPROVAL STAMP
Project:	Notes:
Address:	
Contractor:	
Engineer:	
Date:	
Approved      Approved as Noted      Not Approved	